

Message

From: Moore, Kendall [moore.kendall@epa.gov]
Sent: 9/9/2016 9:05:48 PM
To: Mannix, John [mannixj@monroe.wednet.edu]; Jeff Ketchel [jketchel@snohd.org]; Mullin, Michelle [Mullin.Michelle@epa.gov]
CC: Dekka Smith [smithf@monroe.wednet.edu]; Devlin Piplic [piplicd@monroe.wednet.edu]; Karen Rosencrans [RosencransK@monroe.wednet.edu]; Peachey, Robert [peachey.robert@epa.gov]; Nancy Bernard [nancy.bernard@doh.wa.gov]; Amanda Zych [azych@snohd.org]; Kevin Plemel [kplemel@snohd.org]; Ramanauskas, Peter [ramanauskas.peter@epa.gov]; Mangino, Mario [mangino.mario@epa.gov]
Subject: RE: Completion of SVEC Corrective Action Plan

Thank you for your completion report. In order to fully evaluate your results EPA requests the following:

1. Final QA/QC data for the wipe samples of small gym floor and exterior of Annex Building
2. Area (in square feet) of small gym floor and area exterior of Annex building that were re-cleaned
3. Rational for collecting one sample of the floor in the small gym
4. Please report all air sample quantitation limits/reporting limits as ng/m³
5. Were the wipe samples collected after caulk removal collected before or after epoxy encapsulation?
6. Explain the filter analysis procedure used for air samples run under Method TO-10A.

From: Mannix, John [mailto:mannixj@monroe.wednet.edu]
Sent: Friday, September 09, 2016 1:57 PM
To: Jeff Ketchel ; Mullin, Michelle ; Moore, Kendall
Cc: Dekka Smith ; Devlin Piplic ; Karen Rosencrans ; Nancy Bernard ; Amanda Zych ; Kevin Plemel
Subject: Re: Completion of SVEC Corrective Action Plan

Attached please find the revised notice of completion of the Corrective Action Plan for Sky Valley Education Center. I am not re-sending the twenty attachments containing the lab results and chain of custody documents. Those are all still valid and appropriate. I am therefore simply adding the two new documents related to the re-testing of the PCB wipe test results that previously exceeded 10 ug/100 cm².

Respectfully,

John Mannix
Assistant Superintendent for Operations

200 E. Fremont Street
Monroe, WA 98272
(360) 804-2579



Monroe Public Schools provides an outstanding education that results in all students having a passion for learning.

Any dissemination or use of this information by a person other than the intended recipient is unauthorized and may be illegal. If you have received this e-mail in error, please immediately notify us by return e-mail. All email to and from this domain is archived as a public record in compliance with federal and state requirements. As such they may be both discoverable in a legal action and available through a public records request.